

Date: May 24, 2021
Project: Coffee Creek Outfall Replacement – RFX # 3160004282
Owner: Mississippi Department of Marine Resources
To: Prospective Bidders
RE: Addendum No. 2

This Addendum Number 2 Questions and Answers

1. For bond purposes, what is the estimated cost of the project? **\$1.65 - \$1.7 million dollars**
2. Is there a “Basis of design” on the precast fire pit. I have searched and found no precast fire pits that are 8’-0” DIA. Would a precast “riser ring” or other suitable, modified, precast manhole section fabricated by a precast manhole fabricator work in this instance? **Fire pits shall be similar to the existing fire pits currently in use on the beach. Construction details for the fire pits are shown on Dwg. A-305 with adequate reinforcing to be designed by the contractor. Existing fire pits on the beach were fabricated locally by a precaster.**
3. Same question on the precast concrete benches – Is there a “Basis of design” on these? **Overall size for the benches is shown on Dwg. A-001 – exterior surfaces shall be smooth and painted with deck coating as specified – all other design criteria, including positive anchorage, will be left up to the contractor. Bench construction was coordinated with a local precaster during the design phase.**

Signature